

Schedule of Accreditation

issued by

United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <p>6123 Type C Inspection Body</p> <p>Accredited to ISO/IEC 17020:2012</p>	SOCOTEC UK Limited	
	Issue No: 005 Issue date: 02 January 2018	
SOCOTEC House Bretby Business Park Ashby Road Bretby Burton upon Trent Staffordshire DE15 0YZ	Contact: Mr A.Watkinson Tel: +44 (0)1283 554400 Fax: +44 (0)1283 554422 E-Mail: accreditations@socotec.com Website: www.socotec.co.uk	
Inspection performed at/from the locations specified below		

Locations covered by the organisation and their relevant activities

Location details	Activity	Location code
<p>Address SOCOTEC House Bretby Business Park Ashby Road Bretby Burton upon Trent Staffs DE15 0YZ</p> <p>Local contact Mr P.Sear Tel: +44 (0)1283 554400 Fax: +44 (0)1283 554422 Email: salesuk@socotec.com</p>	<p>Inspection Activities:</p>	A
<p>Address 2-8 Langlands Place Kelvin South Business Park East Kilbride G75 0YF</p> <p>Local contact Mr D.Gilmour Tel: +44 (0)7949645479 Fax: +44 (0)1355 246730 Email: salesuk@socotec.com</p>	<p>Inspection Activities:</p>	B
<p>Address Unit D 2 Wilkinson Road Bankside Business Park Cirencester Gloucestershire GL7 1YT</p> <p>Local contact Mr K.Woods Tel: +44 (0)1285 700593 Email: salesuk@socotec.com</p>	<p>Inspection Activities:</p>	C



6123
 Type C
 Inspection Body
 Accredited to
 ISO/IEC 17020:2012

Schedule of Accreditation
 issued by
United Kingdom Accreditation Service
 2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

SOCOTEC UK Limited

Issue No: 005 Issue date: 02 January 2018

Inspection performed at/from main address only

DETAIL OF ACCREDITATION

Field of Inspection	Type and Range of Inspection	Methods and Procedures	Location Code
Legionella Risk assessments	Cooling towers Domestic hot/cold systems, Spa pools Other systems containing water which is likely to exceed 20°C which may release a spray or aerosol during operation of when being maintained	Documented In-House Methods Manual, based on ACoP L8 and BS 8580:2010 Method ENV 500	A,B,C
	Water Sampling for the purpose of legionella risk assessments: legionella, TVC, Coliforms, E. Coli and pseudomonas aeruginosa	Method ENV 458	A,B,C
	Water testing for the purpose of Legionella risk assessment: temperature	Method ENV 452	A,B,C
END			